

From Fire Station Officer

MC Kaithal

To M/s Amrender Singh Khara
Near Kanya School Village Siwan

Memo No. FS/2021/1 dated : 24/06/2021

Subject : Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group B- Educational Building at Village Siwan Dist Kaithal of SIWAN PUBLIC SCHOOL :

Reference your Transaction Id 090592123000004 dated: 17/06/2021 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Kaithal. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions:-

Tower Name	Floor Detail	Terrace Height of Last Livable Floor(In Meters)	Ground Coverage
Block 1	G+02	11.88 Mtrs	1213.47 SQM
Tower Name	Basement Level	Basement Area	Basement Remarks
	Nil	Nil	Nil

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building

Remarks:- Approved by DMC Kaithal 45 46 47 Dated 23 06 2021



Fire Station Officer,
MC Kaithal

Exercising the power of Director, Fire Services, Haryana



Digitally signed by GURMAIL
SINGH BOUSHLA
Date: 2021.06.24 14:14:05 +05:30
Reason: Digital Verification

प्रेषक

जिला नगर आयुक्त,
कैथल।

सेवा में

दमकल केन्द्र अधिकारी,
कैथल।

क्रमांक

/एल.एफ.ए./डी.एम.सी. दिनांक

विषय:-

Approval of Revise Fire Fighting Scheme of Educatinal Building of Siwan Public School, Village- Siwan & Distt. Kaithal Haryana.

यादी

उपरोक्त विषय आपके कार्यालय के पत्र क्रमांक FSK/294 दिनांक 17.06.2021 के सन्दर्भ में।

विषयाधीन मामलें में आप द्वारा सन्दर्भित पत्र के माध्यम से Educatinal Building of Siwan Public School, Village- Siwan & Distt. Kaithal Haryana के लिए मांगी गई Revise Fire Fighting Scheme की अनुमति नियमानुसार प्रदान करते हुए आपको लिखा जाता है कि आप उक्त Revise Fire Fighting Scheme को विभाग की साईट पर Online Upload करना सुनिश्चित करें।

कृते: जिला नगर आयुक्त,
कैथल।

पू०क्रमांक 4546-47/एल.एफ.ए./डी.एम.सी./दिनांक 23/06/21
इसकी एक-2 प्रति निम्नलिखित को सूचनार्थ एवं आवश्यक कार्यवाही हेतु

भेजी जाती है।

1. कार्यकारी अधिकारी, नगर परिषद, कैथल।
2. Siwan Public School, Village- Siwan & Distt. Kaithal Haryana

कृते: जिला नगर आयुक्त,
कैथल।